



GOVERNMENT OF TRIPURA  
DIRECTORATE OF FIRE & EMERGENCY  
SERVICES  
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSCTFES/2022/00026

Dated: 01/10/2022

**Sub: FIRE SAFETY CERTIFICATE**

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Keimazirswam Kaipeng			
Name of Owner with Plot details:-	<b>S. No.</b>	<b>Owner Name and Address</b>		
	1.	দং বেরীয়ান ওয়েল ফায়ার সোসাইটি পক্ষে সেক্রেটারী সাং- বালু ধুম পাড়া মান্দাই		
	<b>S. No.</b>	<b>Plot No</b>	<b>Total Area</b>	<b>Classification</b>
	1.	11451/140970	4.5	টীলা
Name of the Property/ Organization/ Commercial establishment	Berean English Medium School			
Address of the Building/ Premises:-	Tilla Habitation, Ashighar Village Council, Mandwai Bac Block, Post Office Ashigharh B.O - 799045, West Tripura District, Tripura.			

Director,  
Fire & Emergency Services,  
Or Authorized Signatory  
Tripura : Agartala


This certificate will expire on 01/10/2025

**Conditions for the Validity of Fire Safety Certificate (NOC).**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Fire Safety Certificate (NOC) is being issued in favour of "Berean English Medium School" applicant Name: Shri Keirmazirswam Kaipeng and this NOC is valid only for the specific area occupying by this School.

Validity unknown

Digitally signed by  Signer Name

Date: 2022.10.04 14:00:02 IST